



REPORT

Unstable Areas Demonstration

Escalante Station Active Coal Combustion Residuals Landfill

Submitted to:

Tri-State Generation and Transmission Association, Inc.

1100 West 116th Avenue, Westminster, Colorado 80234

Submitted by:

Golder Associates Inc.

44 Union Boulevard, Suite 300 Lakewood, Colorado 80228

+1 303 980-0540

1783558

October 10, 2018




Table of Contents

1.0 INTRODUCTION 1

 1.1 Background 1

 1.2 Facility Information 1

2.0 UNSTABLE AREA ASSESSMENT 1

 2.1 Requirements 1

 2.2 Review of Available Information 1

 2.3 Geotechnical and Geologic Information 2

 2.4 Findings 2

3.0 CONCLUSION 3

4.0 REFERENCES 4

FIGURE

Quaternary Faults and Karst Features in Proximity to Escalante CCR Facility

APPENDICES

APPENDIX A

Global Slope Stability Calculations

1.0 INTRODUCTION

1.1 Background

Golder Associates Inc. (Golder) has prepared this report for Tri-State Generation and Transmission Association, Inc. (Tri-State) to summarize our assessment of the active coal combustion residuals (CCR) landfill (the Facility) at Tri-State's Escalante Generating Station (the site) with respect to factors that could cause an area to be considered an unstable area, and to provide supporting information demonstrating that the Facility is not located in an unstable area. This report includes written certification by a qualified professional engineer registered in New Mexico stating that the Facility is not located in an unstable area and is in compliance with 40 CFR 257.64.

1.2 Facility Information

The Facility is located less than a mile east of the power block at Tri-State's Escalante Generating Station, a 270-megawatt coal-fired electric generation plant located in McKinley County, New Mexico. It serves as the location for final deposition of CCRs generated at Escalante Generating Station and classifies as an existing CCR landfill under 40 CFR 257.

2.0 UNSTABLE AREA ASSESSMENT

2.1 Requirements

An unstable area is defined under 40 CFR 257.53 as follows:

Unstable area means a location that is susceptible to natural or human-induced events or forces capable of impairing the integrity, including structural components of some or all of the CCR unit that are responsible for preventing releases from such unit. Unstable areas can include poor foundation conditions, areas susceptible to mass movements, and karst terrains.

Under 40 CFR 257.64(b), the following factors, at a minimum, must be considered as part of the assessment to determine whether the Facility is located in an unstable area:

- On-site or local soil conditions that may result in significant differential settling
- On-site or local geologic or geomorphologic features
- On-site or local human-made features or events (both surface and subsurface)

2.2 Review of Available Information

Golder reviewed the following information in the course of completing the unstable area assessment:

- Groundwater monitoring plan for the site (Metric Corporation 1983)
- Engineering design report for the Facility (Metric Corporation 2006)
- Quaternary faults and folds dataset for the United States (United States Geological Survey and New Mexico Bureau of Mines and Mineral Resources 2006)
- Karst dataset for the United States (Weary and Doctor 2014)
- 2015 annual inspection report for the Facility (Golder 2016a)
- Drilling and monitoring well installation summary for the Facility (Golder 2016b)

- 2016 annual inspection report for the Facility (Golder 2017)
- 2017 annual inspection report for the Facility (Golder 2018)

In addition to the review of available information, the professional engineer overseeing the unstable area assessment has visited and observed the Facility on several occasions, including the site visits associated with annual inspections conducted for compliance with 40 CFR 257.84(b)(1) in 2015, 2016, and 2017, and has visually assessed the factors that could cause the area within and in close proximity to the Facility to be considered an unstable area.

2.3 Geotechnical and Geologic Information

Near-surface geology at the site is generally characterized by Quaternary alluvium underlain by bedrock of the Triassic Chinle Formation, Petrified Forest Member. Within the Chinle Formation is the Correo sandstone bed, which is confined on the top and bottom by Chinle claystone, upper part.

The surficial Quaternary alluvium generally ranges from approximately 10 to 25 feet thick near the Facility, and the Chinle claystone overlying the Correo sandstone bed ranges from approximately 100 to 200 feet thick in the area (Golder 2016b). The Correo sandstone bed is approximately 50 feet thick beneath the Facility, and the Chinle claystone underlying the Correo sandstone bed is several hundred feet thick (Golder 2016b).

Quaternary alluvium in the vicinity of the Facility consists primarily of clayey sand, silty sand, or sandy clay (Golder 2016c). For purposes of accumulating soil resources for Facility construction and closure, Tri-State has excavated the surficial soils to a nominal depth of 5 feet and stockpiled the excavated material before expanding the Facility footprint into a given area.

2.4 Findings

Golder's review of available information and knowledge of the Facility indicate the following with respect to factors that could cause an area to be considered an unstable area:

- On-site or local soil conditions that may result in significant differential settling
 - The thickness of unconsolidated material (Quaternary alluvium) at the site prior to construction of the Facility is limited, generally ranging from 10 to 25 feet (Golder 2016b). Further reducing the thickness of unconsolidated material beneath the Facility, Tri-State has excavated the surficial soils to a nominal depth of 5 feet before constructing or expanding the Facility footprint into a given area.
 - Quaternary alluvium found at the site consists primarily of soils characterized as clayey sand, silty sand, or sandy clay (Golder 2016c). These soil types are not commonly prone to high compressibility.
 - No evidence of differential settlement has been observed at the Facility during annual inspections by a qualified professional engineer (Golder 2016a, Golder 2017, Golder 2018).
 - Given the limited thickness of unconsolidated material beneath the Facility, the characteristics of the unconsolidated material (i.e., not commonly prone to high compressibility), and site observations, Golder concludes that there are not on-site or local soil conditions that may result in significant differential settling.

- On-site or local geologic or geomorphologic features
 - The Facility is not located in an area with geological conditions that create the potential for karst terrain or features, as shown in Figure 1.
 - The Facility is not located in an area with known faults or folds that demonstrate geological evidence of coseismic surface deformation during the Quaternary Period, as shown in Figure 1.
 - Site topography is gentle, sloping at an average grade of 1 percent from west to east in the vicinity of the Facility. The Facility is higher in elevation than the surrounding topography around its east, south, and west sides. Along its north side, it abuts an inactive CCR landfill that shows no evidence of mass movement. As such, the Facility is not susceptible to instability related to mass movement (e.g., landslides, avalanches, debris flows, solifluction, block sliding, or rock fall) from adjacent areas.
 - No evidence of faulting, rock fall, landslides, or local soil conditions that are conducive to downslope movement of soil, rock, or debris have been observed at the Facility during annual inspections by a qualified professional engineer (Golder 2016a, Golder 2017, Golder 2018).
- On-site or local human-made features or events (both surface and subsurface)
 - There are no known historical mine workings at the site. Geotechnical investigations at the site have not identified coal seams or other subsurface resources that may have motivated mining at the site.
 - Slope stability analyses for the Facility indicate a factor of safety equal to 1.7 for static conditions and a factor of safety equal to 1.1 under design seismic loading. The slope stability analyses for the Facility are summarized in Appendix A.
 - No human-made features having the potential to create unstable conditions have been observed at the Facility during annual inspections by a qualified professional engineer (Golder 2016a, Golder 2017, Golder 2018).

3.0 CONCLUSION

Based upon the assessment described in this report, the undersigned professional engineer registered in New Mexico certifies that the active CCR landfill at Escalante Generating Station is not located in an unstable area and is in compliance with 40 CFR 257.64.

4.0 REFERENCES

Golder Associates Inc. (2016a). Coal Combustion Residuals Landfill Annual Inspection Report. Report prepared for Tri-State Generation and Transmission Association, Inc. Project number 1533418CCR. January 18, 2016.

Golder Associates Inc. (2016b). Drilling and Monitoring Well Installation Summary at the Escalante Generating Station in Prewitt, New Mexico. Technical memorandum prepared for Tri-State Generation and Transmission Association, Inc. Project number 1533418GW. August 19, 2016.

Golder Associates Inc. (2016c). Assessment of Final Cover Hydraulic Performance. Report prepared for Tri-State Generation and Transmission Association, Inc. Project number 1663066. October 2016.

Golder Associates Inc. (2017). Coal Combustion Residuals Landfill Annual Inspection Report. Report prepared for Tri-State Generation and Transmission Association, Inc. Project number 1663066. January 18, 2017.

Golder Associates Inc. (2018). Active Coal Combustion Residuals Landfill Annual Inspection Report. Report prepared for Tri-State Generation and Transmission Association, Inc. Project number 1783558. January 15, 2018.

Metric Corporation (1983). Ground-Water Monitoring Plan for the Plains Escalante Generating Station No. 1. Report prepared for Plains Electric Generation and Transmission Cooperative, Inc.

Metric Corporation (2006). Scrubber Sludge/Fly Ash Landfill Expansion Plan for the Tri-State Escalante Generating Station. Report prepared for Tri-State Generation and Transmission Association, Inc. August 14, 2006.

United States Geological Survey and New Mexico Bureau of Mines and Mineral Resources (2006). Quaternary Fault and Fold Database for the United States. Available online: <http://earthquake.usgs.gov/hazards/qfaults>. Accessed September 12, 2018.


Weary, D.J., and D.H. Doctor (2014). Karst in the United States: A Digital Map Compilation and Database. United States Geological Survey Open-File Report 2014-1156. Available online: <https://pubs.usgs.gov/of/2014/1156/pdf/of2014-1156.pdf>. Accessed September 12, 2018.

Signature Page


Golder Associates Inc.



Jason Obermeyer, P.E.
Associate and Senior Consultant



Todd Stong, P.E.
Associate and Senior Consultant





October 10, 2018

Golder and the G logo are trademarks of Golder Associates Corporation

https://golderassociates.sharepoint.com/sites/15537g/deliverables/reports/escalante_unstable_areas_demonstration_fnl_10oct18/1783558-0008--2-r-0-escalante_ccr_unstable_areas_demonstration_10oct18.docx

Figure



- LEGEND**
- SITE LOCATION
 - 10-MILE RADIUS FROM SITE
 - 25-MILE RADIUS FROM SITE
 - QUATERNARY FAULT (NONE WITHIN MAP EXTENTS)
- KARST TYPE**
- FISSURES, TUBES AND CAVES GENERALLY LESS THAN 1,000 FT (300 M) LONG; 50 FT (15 M) OR LESS VERTICAL EXTENT; IN GENTLY DIPPING TO FLAT-LYING BEDS OF CARBONATE ROCK
 - FISSURES, TUBES, AND TUNNELS PRESENT TO A DEPTH OF 50 FT. (15 M) IN LAVA



- REFERENCES**
1. DIGITAL ENGINEERING ASPECTS OF KARST MAP : A GIS VERSION OF DAVIES, W.E., SIMPSON, J.H., OHLMACHER, G.C., KIRK, W.S., AND NEWTON, E.G., 1984, ENGINEERING ASPECTS OF KARST: U.S. GEOLOGICAL SURVEY, NATIONAL ATLAS OF THE UNITED STATES OF AMERICA, SCALE 1:7,500,000 BY BRET D. TOBIN AND DAVID J. WEARY U.S. GEOLOGICAL SURVEY OPEN-FILE REPORT 2004-1352
 2. QUATERNARY FAULTS DATASET: U.S. GEOLOGICAL SURVEY AND NEW MEXICO BUREAU OF MINES AND MINERAL RESOURCES, 2006, QUATERNARY FAULT AND FOLD DATABASE FOR THE UNITED STATES, ACCESSED SEPTEMBER 2018, FROM USGS WEB SITE: [HTTP://EARTHQUAKE.USGS.GOV/HAZARDS/QFAULTS/](http://earthquake.usgs.gov/ hazards/ qfaults/).
 3. BASEMAP: ESRI, DIGITAL GLOBE, VIVID, 2017.

CLIENT
TRI-STATE GENERATION AND TRANSMISSION ASSOCIATION, INC.

PROJECT
UNSTABLE AREAS DEMONSTRATION

TITLE
**QUATERNARY FAULTS AND KARST FEATURES
IN PROXIMITY TO ESCALANTE CCR FACILITY**

CONSULTANT	DATE	BY
	YYYY-MM-DD	2018-10-09
	DESIGNED	KJC
	PREPARED	KJC
	REVIEWED	JEO
	APPROVED	TJS

PROJECT NO. 1783558 FIGURE 1

PATH: M:\GIS\Bare_Escalante\Kest\Kest.mxd PRINTED ON: 2018-10-09 AT: 3:30:05 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI B

APPENDIX A

Global Slope Stability Calculations

CALCULATIONS

DATE	October 9, 2018	PREPARED BY	JEO
DOCUMENT NO.	1783558	CHECKED BY	CCS
SITE NAME	Escalante Generating Station Active Coal Combustion Residuals Landfill	REVIEWED BY	TJS

GLOBAL SLOPE STABILITY ANALYSIS

1.0 OBJECTIVE

Evaluate the global slope stability of the active coal combustion residuals (CCR) landfill at the Escalante Generating Station (the landfill) at final closure. The analysis assesses the stability of the landfill using grades shown in the Closure Plan (Golder 2016).

2.0 METHODOLOGY

A typical cross section at the landfill's full design height (final closure grades) was developed for global slope stability analysis. Limit equilibrium slope stability analyses were performed using Spencer's method in Slide 8.0, a two-dimensional slope stability modeling software platform (Rocscience 2018). Spencer's method considers both moment and force equilibrium. It is common geotechnical practice to analyze the stability of embankment slopes using limit equilibrium methods.

The slope stability analyses focus on circular slip surfaces that pass into the CCRs contained in the landfill (minimum depth of 4 feet). Slope stability analyses were performed to evaluate the minimum factors of safety under static and seismic loading conditions.

2.1 Geometry

The cross section was taken through the longest existing embankment slope, which is also expected to be the longest embankment slope at final closure. A plan view showing the cross section location is included as Figure A-1.

2.2 Analysis

The slope stability analyses were predicated on the following assumptions:

- Factors of safety were computed using Spencer's method (Spencer 1967).
- The seismic hazard analysis reported by the United States Geological Survey (2014) indicates a 2% probability of exceeding a peak ground acceleration (PGA) of 0.10 g in 50 years at the site (see Attachment A-1). Pseudo-static analyses were conducted using a horizontal seismic coefficient of 0.05, corresponding to half of the PGA, in accordance with the recommendations of Hynes-Griffin and Franklin (1984).
- Strength properties for cover soil and foundation soil (i.e., site soil) were selected based on the results of consolidated-undrained triaxial testing performed on soil sampled from a stockpile that serves as a borrow source for final cover system construction (refer to Attachment A-2).

CALCULATIONS

DATE October 9, 2018

PREPARED BY JEO

DOCUMENT NO. 1783558

CHECKED BY CCS

SITE NAME Escalante Generating Station Active
Coal Combustion Residuals Landfill

REVIEWED BY TJS

GLOBAL SLOPE STABILITY ANALYSIS

- Site soil was assumed to exhibit drained strengths under static loading and undrained strengths under seismic loading. A 20% reduction was applied to site soil undrained strengths in the seismic analyses, as recommended by Hynes-Griffin and Franklin (1984).
- Site soil density was selected based on the average initial density in the consolidated-undrained triaxial test.
- The bedrock underlying the CCRs was assumed to have infinite strength, constraining slip surfaces to the cover soil, CCRs, and foundation soil.
- The top of the bedrock layer was assumed to be at a depth of 30 feet below the pre-landfill ground surface, based on findings from subsurface investigations conducted in the vicinity of the landfill. The floor grades for the landfill were assumed to involve excavation to a depth of 5 feet below the pre-landfill ground surface, based on Golder's understanding and observation of typical construction practices for the landfill.
- Strength properties for CCRs were selected based on the results of consolidated-undrained triaxial testing performed on comingled ash sampled from the landfill (refer to Attachment A-3). CCRs were assumed to exhibit drained strengths under static and seismic loading conditions, and no strength reduction was applied for seismic analyses.
- Density of CCRs was selected based on the average initial density in the consolidated-undrained triaxial test.
- CCRs were assumed to be unsaturated based on site observation.

2.3 Material Properties

A summary of material properties used in the slope stability analyses is presented in Table A-1:

Table A-1: Material Properties

Condition	Material	Total Unit Weight (pcf)	Strength Type	Friction Angle (°)	Cohesion (psf)
Static Loading	Bedrock	120	Infinite Strength	--	--
Seismic Loading					
Static Loading	CCRs	94	Mohr-Coulomb	32	0
Seismic Loading					
Static Loading	Site Soil (Cover Soil and Foundation Soil)	115	Mohr-Coulomb	30	0
Seismic Loading			Shear-Normal Function ¹	--	--

Note:

- 1) The shear-normal function defining the undrained strength of site soil is based on the results of consolidated-undrained triaxial testing, with a 20% reduction for cyclic loading, as follows: shear strength of 80 psf under zero initial effective stress; shear strength of 179 psf under 864-psf initial effective stress; shear strength of 256 psf under 1,440-psf initial effective stress; shear strength of 2,213 psf under 7,200-psf initial effective stress.

CALCULATIONS

DATE	October 9, 2018	PREPARED BY	JEO
DOCUMENT NO.	1783558	CHECKED BY	CCS
SITE NAME	Escalante Generating Station Active Coal Combustion Residuals Landfill	REVIEWED BY	TJS

GLOBAL SLOPE STABILITY ANALYSIS

3.0 RESULTS AND CONCLUSIONS

Results of the slope stability analyses are as follows:

- Minimum computed factor of safety = 1.7 under static loading
- Minimum computed factor of safety = 1.1 under seismic loading

The results are also illustrated graphically on the figures in Attachment A-4. The figures depict the critical slip surfaces and computed minimum factors of safety for the analyzed scenarios.

Based on the factors of safety computed using the methods and assumptions described herein, the landfill is expected to remain stable with an acceptable safety margin. A factor of safety greater than 1.5 was computed for critical slip surfaces passing into the CCRs under static loading. A factor of safety greater than 1.0 was computed for critical slip surfaces passing into the CCRs under seismic loading.

4.0 REFERENCES

Golder Associates Inc. 2016. Escalante Generating Station Active Ash Landfill Closure Plan. Report prepared for Tri-State Generation and Transmission Association, Inc. Project number 1663066. October 2016.


Hynes-Griffin, M. and A. Franklin. 1984. Rationalizing the Seismic Coefficient Method. Miscellaneous Paper GL-84-13. US Army Engineer Waterways Experiment Station, Vicksburg, MS.

Rocscience Inc. 2018. Slide Version 8.016. Build date: July 23, 2018.

Spencer, E. 1967. A Method of Analysis of the Stability of Embankments Assuming Parallel Inter-Slice Forces. Geotechnique, Vol. XVII, No. 1, pp. 11–26.

United States Geological Survey. 2014. PGA with 2% probability of exceedance in 50 years, USGS map, 2014 rev. Available online: <https://earthquake.usgs.gov/static/lfs/nshml/conterminous/2014/2014pga2pct.pdf>. Accessed September 14, 2018.

FIGURE



LEGEND
 ——— EXISTING GROUND SURFACE CONTOURS
 ——— PROPOSED GROUND SURFACE CONTOURS

INACTIVE LANDFILL

ACTIVE LANDFILL

3H:1V (TYP. INTERBENCH)

2.0%

2.0%

2.0%

2.0%



CLIENT
 TRI-STATE GENERATION AND TRANSMISSION
 ASSOCIATION, INC.

PROJECT
 ESCALANTE GENERATING STATION
 ACTIVE COAL COMBUSTION RESIDUALS LANDFILL

TITLE
 SLOPE STABILITY CROSS SECTION LOCATION


CONSULTANT	YYYY-MM-DD	2018-09-14
DESIGNED	JEO	
PREPARED	JEO	
REVIEWED	CCS	
APPROVED	TJS	

PROJECT NO. 1783558 PHASE 0008 REV. A FIGURE A-1

Path: \\DENVER\J\JFS\golder\gfs\landfill\161683066\PRODUCTION\SV\Control\0001.T File Name: Figure A-1.dwg

1 in IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSI D

ATTACHMENT A-1



CLIENT
TRI-STATE GENERATION AND TRANSMISSION ASSOCIATION, INC.

PROJECT
**ESCALANTE GENERATING STATION
 ACTIVE COAL COMBUSTION RESIDUALS LANDFILL**

CONSULTANT

YYYY-MM-DD 2018-09-14
 PREPARED JEO
 DESIGN JEO
 REVIEW CCS
 APPROVED TJS

TITLE
**TWO PERCENT PROBABILITY OF EXCEEDANCE IN 50 YEARS
 MAP OF PEAK GROUND ACCELERATION**



PROJECT No.
1783558

Rev.
A

ATTACHMENT
A-1

1 in IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSI A

ATTACHMENT A-2

Boring or Test Pit: --
 Sample: Site Soil
 Depth: 1 ft
 Point No.: 1

Boring or Test Pit: --
 Sample: Site Soil
 Depth: 1 ft
 Point No.: 2

Boring or Test Pit: --
 Sample: Site Soil
 Depth: 1 ft
 Point No.: 3

Initial
 Length = 5.737 in
 Diameter = 2.859 in
 Wet Mass = 2.480 lb
 Area = 6.420 in²
 Volume = 36.830 in³
 Specific Gravity = 2.68 (ASTM D854)
 Dry Mass of Solids = 2.371 lb
 Moisture Content = 4.6%
 Wet Unit Weight = 116.4 pcf
 Dry Unit Weight = 111.2 pcf
 Void Ratio = 0.50
 Percent Saturation = 25%

Initial
 Length = 5.769 in
 Diameter = 2.872 in
 Wet Mass = 2.480 lb
 Area = 6.478 in²
 Volume = 37.373 in³
 Specific Gravity = 2.68 (ASTM D854)
 Dry Mass of Solids = 2.373 lb
 Moisture Content = 4.5%
 Wet Unit Weight = 114.7 pcf
 Dry Unit Weight = 109.7 pcf
 Void Ratio = 0.52
 Percent Saturation = 23%

Initial
 Length = 5.769 in
 Diameter = 2.863 in
 Wet Mass = 2.477 lb
 Area = 6.438 in²
 Volume = 37.139 in³
 Specific Gravity = 2.68 (ASTM D854)
 Dry Mass of Solids = 2.368 lb
 Moisture Content = 4.6%
 Wet Unit Weight = 115.3 pcf
 Dry Unit Weight = 110.2 pcf
 Void Ratio = 0.52
 Percent Saturation = 24%

After Consolidation
 Length = 5.786 in
 Diameter = 2.854 in
 Area = 6.399 in² (Method B)
 Volume = 37.027 in³
 Moisture Content = 19.0%
 Wet Unit Weight = 131.7 pcf
 Dry Unit Weight = 110.7 pcf
 Void Ratio = 0.51
 Percent Saturation = 100%

After Consolidation
 Length = 5.674 in
 Diameter = 2.881 in
 Area = 6.519 in² (Method B)
 Volume = 36.990 in³
 Moisture Content = 18.9%
 Wet Unit Weight = 131.8 pcf
 Dry Unit Weight = 110.9 pcf
 Void Ratio = 0.51
 Percent Saturation = 100%

After Consolidation
 Length = 5.632 in
 Diameter = 2.782 in
 Area = 6.077 in² (Method B)
 Volume = 34.226 in³
 Moisture Content = 14.8%
 Wet Unit Weight = 137.3 pcf
 Dry Unit Weight = 119.6 pcf
 Void Ratio = 0.40
 Percent Saturation = 100%

B Parameter = 0.95
 Shear Rate = 0.084% /min.
 t₅₀ = -- (not computed)
 Strain at Failure = 8.6%

B Parameter = 0.95
 Shear Rate = 0.083% /min.
 t₅₀ = -- (not computed)
 Strain at Failure = 6.6%

B Parameter = 0.80
 Shear Rate = 0.063% /min.
 t₅₀ = 6.3 min.
 Strain at Failure = 15.2%

Cell Pressure = 106 psi
 Back Pressure = 100 psi
 Confining Pressure = 6 psi

Cell Pressure = 110 psi
 Back Pressure = 100 psi
 Confining Pressure = 10 psi

Cell Pressure = 150 psi
 Back Pressure = 100 psi
 Confining Pressure = 50 psi

Notes: USCS description (ASTM D 2487): Clayey sand, dry, red
 Atterberg limits: LL = 22 PL = 13 PI = 9 (ASTM D4318)
 Percent finer: 3/4 in. = 100% No. 4 = 99% No. 200 = 41% (ASTM D422, refer to separate report for gradation curve)
 Specimen type:

	Intact	X
	Cuttings	X

 Reconstituted Remold targets: 110.4 pcf (dry) at 4.9% moisture
 Moisture from:

	Wet	
	Dry	

 Entire specimen
 Saturation method:

X	Wet	
	Dry	



 Failure criterion:

	(σ ₁ /σ ₃) _{max}	X	(σ ₁ -σ ₃) _{max}		% strain
--	--	---	--	--	----------

 Membrane effect:


X	Corrected		Not Corrected
---	-----------	--	---------------

Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT SAMPLE AND TEST DATA			
Job Short Title: Tri-State/Escalante Station/CO		Technician: BC		Reviewed: JO	Date: 1/21/2016
Sample: Site Soil		Job Number: 1533418CCR	Figure: 1		



Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT q AND EXCESS PORE PRESSURE PLOTS			
Job Short Title: Tri-State/Escalante Station/CO					
Sample: Site Soil	Technician: BC	Reviewed: JO	Date: 1/21/2016	Job Number: 1533418CCR	Figure: 2

Stress Path (p'-q) Plot



Confining Pressure (psi)	p at failure (psi)	p' at failure (psi)	q at failure (psi)
6	7.6	5.3	1.6
10	12.2	9.0	2.2
50	69.2	35.9	19.2

**Golder Associates Inc.
Denver, Colorado**

Title:

ASTM D4767
CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
STRESS PATH PLOT

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

Site Soil

Technician:

BC

Reviewed:

JO

Date:

1/21/2016


Job Number:

1533418CCR

Figure:

3

Mohr's Circle Diagram



Confining Pressure (psi)	σ'_1 at failure (psi)	σ'_3 at failure (psi)	σ_1 at failure (psi)	σ_3 at failure (psi)
6	6.9	3.7	9.1	6.0
10	11.2	6.8	14.4	10.0
50	55.1	16.7	88.4	50.0

Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT MOHR'S CIRCLE DIAGRAM			
Job Short Title: Tri-State/Escalante Station/CO					
Sample: Site Soil	Technician: BC	Reviewed: JO	Date: 1/21/2016	Job Number: 1533418CCR	Figure: 4



Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT SPECIMEN PHOTOGRAPH - 6 psi			
Job Short Title: Tri-State/Escalante Station/CO					
Sample: Site Soil	Technician: BC	Reviewed: JO	Date: 1/21/2016	Job Number: 1533418CCR	Figure: 5



Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT SPECIMEN PHOTOGRAPH - 10 psi			
Job Short Title: Tri-State/Escalante Station/CO					
Sample: Site Soil	Technician: BC	Reviewed: JO	Date: 1/21/2016	Job Number: 1533418CCR	Figure: 6



Golder Associates Inc. Denver, Colorado		Title: ASTM D4767 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT SPECIMEN PHOTOGRAPH - 50 psi			
Job Short Title: Tri-State/Escalante Station/CO					
Sample: Site Soil	Technician: BC	Reviewed: JO	Date: 1/21/2016	Job Number: 1533418CCR	Figure: 7

ATTACHMENT A-3

Boring or Test Pit: --
 Sample: LF Ash
 Depth: 3 ft
 Point No.: 1

Boring or Test Pit: --
 Sample: LF Ash
 Depth: 3 ft
 Point No.: 2

Boring or Test Pit: --
 Sample: LF Ash
 Depth: 3 ft
 Point No.: 3

Initial
 Length = 5.705 in
 Diameter = 2.879 in
 Wet Mass = 2.016 lb
 Area = 6.510 in²
 Volume = 37.139 in³
 Specific Gravity = 2.28 (ASTM D854)
 Dry Mass of Solids = 1.676 lb
 Moisture Content = 20.3%
 Wet Unit Weight = 93.8 pcf
 Dry Unit Weight = 78.0 pcf
 Void Ratio = 0.82
 Percent Saturation = 56%

Initial
 Length = 5.737 in
 Diameter = 2.877 in
 Wet Mass = 2.024 lb
 Area = 6.501 in²
 Volume = 37.295 in³
 Specific Gravity = 2.28 (ASTM D854)
 Dry Mass of Solids = 1.699 lb
 Moisture Content = 19.1%
 Wet Unit Weight = 93.8 pcf
 Dry Unit Weight = 78.7 pcf
 Void Ratio = 0.80
 Percent Saturation = 54%

Initial
 Length = 5.713 in
 Diameter = 2.876 in
 Wet Mass = 2.019 lb
 Area = 6.496 in²
 Volume = 37.113 in³
 Specific Gravity = 2.28 (ASTM D854)
 Dry Mass of Solids = 1.691 lb
 Moisture Content = 19.4%
 Wet Unit Weight = 94.0 pcf
 Dry Unit Weight = 78.7 pcf
 Void Ratio = 0.80
 Percent Saturation = 55%

After Consolidation
 Length = 5.670 in
 Diameter = 2.828 in
 Area = 6.283 in² (Method B)
 Volume = 35.627 in³
 Moisture Content = 32.8%
 Wet Unit Weight = 108.0 pcf
 Dry Unit Weight = 81.3 pcf
 Void Ratio = 0.75
 Percent Saturation = 100%

After Consolidation
 Length = 5.669 in
 Diameter = 2.792 in
 Area = 6.123 in² (Method B)
 Volume = 34.712 in³
 Moisture Content = 29.8%
 Wet Unit Weight = 109.8 pcf
 Dry Unit Weight = 84.6 pcf
 Void Ratio = 0.68
 Percent Saturation = 100%

After Consolidation
 Length = 5.636 in
 Diameter = 2.789 in
 Area = 6.111 in² (Method B)
 Volume = 34.441 in³
 Moisture Content = 29.6%
 Wet Unit Weight = 109.9 pcf
 Dry Unit Weight = 84.8 pcf
 Void Ratio = 0.67
 Percent Saturation = 100%

B Parameter = 0.96
 Shear Rate = 0.033% /min.
 t₅₀ = -- (not computed)
 Strain at Failure = 1.1%

B Parameter = 0.96
 Shear Rate = 0.033% /min.
 t₅₀ = -- (not computed)
 Strain at Failure = 3.1%

B Parameter = 0.97
 Shear Rate = 0.034% /min.
 t₅₀ = -- (not computed)
 Strain at Failure = 7.6%

Cell Pressure = 125 psi
 Back Pressure = 100 psi
 Confining Pressure = 25 psi

Cell Pressure = 150 psi
 Back Pressure = 100 psi
 Confining Pressure = 50 psi

Cell Pressure = 199 psi
 Back Pressure = 100 psi
 Confining Pressure = 99 psi

Notes: USCS description (ASTM D2487): Silt with sand, gray, moist
 Atterberg limits: LL = NP PL = NP PI = NP (ASTM D4318)
 Percent finer: 3/4 in. = 100% No. 4 = 100% No. 200 = 70% (ASTM D422, refer to separate report for gradation curve)
 Specimen type:

	Intact	X
	Cuttings	X

 Reconstituted Remold targets: 78.4 pcf (dry) at 20.0% moisture
 Moisture from:

	Wet	
	Dry	

 Entire specimen
 Saturation method:

X	Wet	
	Dry	

 Failure criterion:

	(σ ₁ /σ ₃) _{max}	X
	(σ ₁ -σ ₃) _{max}	

 % strain
 Membrane effect:

X	Corrected	
	Not Corrected	

Golder Associates Inc.



Title:

ASTM D4767

CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT

SAMPLE AND TEST DATA

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

LF Ash

Technician:

BC

Reviewed:

JO

Date:



12/22/2015

Job Number:

1533418CCR

Figure:

1



Golder Associates Inc.  **Golder Associates**

Title: ASTM D4767
CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
q AND EXCESS PORE PRESSURE PLOTS

Job Short Title:
 Tri-State/Escalante Station/CO

Sample:
 LF Ash

Technician:
 BC


Reviewed:
 JO

Date:
 12/22/2015

Job Number:
 1533418CCR

Figure:
 2

Stress Path (p'-q) Plot



Confining Pressure (psi)	p at failure (psi)	p' at failure (psi)	q at failure (psi)
25	37.9	27.6	12.9
50	83.2	62.4	33.2
99	170.1	131.3	71.1

Golder Associates Inc.  **Golder Associates**

Title:

ASTM D4767
 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
 STRESS PATH PLOT

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

LF Ash

Technician:

BC

Reviewed:

JO

Date:

12/22/2015


Job Number:

1533418CCR

Figure:

3

Mohr's Circle Diagram



Confining Pressure (psi)	σ'_1 at failure (psi)	σ'_3 at failure (psi)	σ_1 at failure (psi)	σ_3 at failure (psi)
25	40.4	14.7	50.7	25.0
50	95.6	29.3	116.3	50.0
99	202.4	60.3	241.2	99.0

Golder Associates Inc.  **Golder Associates**

Job Short Title:
Tri-State/Escalante Station/CO

Title:

ASTM D4767
CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
MOHR'S CIRCLE DIAGRAM

Sample:
LF Ash

Technician:
BC

Reviewed:
JO

Date:
12/22/2015

Job Number:
1533418CCR

Figure:
4



Golder Associates Inc.



Title:

ASTM D4767
 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
 SPECIMEN PHOTOGRAPH - 25 psi

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

LF Ash

Technician:

BC

Reviewed:

JO

Date:

12/22/2015

Job Number:

1533418CCR

Figure:

5



Golder Associates Inc.



Title:

ASTM D4767
 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
 SPECIMEN PHOTOGRAPH - 50 psi

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

LF Ash

Technician:

BC

Reviewed:

JO

Date:

12/22/2015

Job Number:

1533418CCR

Figure:

6



Golder Associates Inc.



Title:

ASTM D4767
 CONSOLIDATED UNDRAINED TRIAXIAL COMPRESSION TEST REPORT
 SPECIMEN PHOTOGRAPH - 99 psi

Job Short Title:

Tri-State/Escalante Station/CO

Sample:

LF Ash

Technician:

BC

Reviewed:

JO

Date:

12/22/2015


Job Number:

1533418CCR

Figure:

7

ATTACHMENT A-4




Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)
CCRs		94	Mohr-Coulomb	0	32
Cover Soil		115	Mohr-Coulomb	0	30
Foundation Soil		115	Mohr-Coulomb	0	30
Bedrock		120	Infinite strength		





1.719



SLIDEINTERPRET 8.016

<i>Project</i>		Escalante Generating Station Active Coal Combustion Residuals Landfill	
<i>Analysis Description</i>		Static Loading	
<i>Drawn By</i>	Jason Obermeyer	<i>Company</i>	Golder Associates Inc.
<i>Date</i>	9/14/2018, 8:35:18 AM	<i>File Name</i>	Static.slim



Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)	Shear Normal Function
CCRs		94	Mohr-Coulomb	0	32	
Cover Soil		115	Shear Normal function			Site Soil
Foundation Soil		115	Shear Normal function			Site Soil
Bedrock		120	Infinite strength			



SLIDEINTERPRET 8.016

<i>Project</i>		Escalante Generating Station Active Coal Combustion Residuals Landfill	
<i>Analysis Description</i>		Seismic Loading	
<i>Drawn By</i>	Jason Obermeyer	<i>Company</i>	Golder Associates Inc.
<i>Date</i>	9/14/2018, 8:35:18 AM	<i>File Name</i>	Pseudostatic2.slim



golder.com